

PROFORMA FOR THE SAFETY CERTIFICATE OF SCHOOL BUILDING  
(PART-I)

(To be filled in by the head of school, institute)

- 1. Name of the School Shabeed Bhagat Singh Int. School
- 2. Location Varpal, Amritsar
- 3. Plot Area 17K 13 Marla (2.2065)
- 4. Plinth Area 25450 Sq. ft.
- 5. Number of Stories Two
- 6. Area of Constructed part of the building \_\_\_\_\_
- 7. If the building has been constructed under the supervision of the qualified Engineer, the following details may be given:-
  - a) Name of Engineer with qualification En. Rattan Singh
  - b) Address of the Engineer 1st Floor, New Market,  
Lawrence Road,  
Amritsar
  - c) If structural drawing used in the construction, if available? \_\_\_\_\_
  - d) Name and address of Architect with qualification \_\_\_\_\_
- 8. Whether the building has been constructed for the purpose of
  - a) School Yes/No
  - b) Residential purpose and used for a school Yes/No
- 9. Materials used for Roofs
  - a) R.C.C.Slabs Yes
  - b) R.S.Joists & Battons -
  - c) Wooden Joints and bottom -
- 10. Material used for Walls
  - a) Mud Mortar Yes/No
  - b) Cement Mortar Yes/No
  - c) Lime Mortar Yes/No
- 11. Flooring
  - a) Conglomerate Yes/No
  - b) Terrace Yes/No
  - c) Brick Paving Yes/No

Principal  
 Shabeed Bhagat Singh International School  
 (Primary & Secondary)  
 Varpal, Amritsar.  
 Affiliated to CBSE  
 Affiliation No. : 1630657  
 School Code - 20640

- b) Terrace
- c) Brick Paving

Yes/No ✓  
Yes/No ✓

12. A detailed drawing indicating the doors alongwith windows and location fitting and windows is attached.

13. FOR FIRE SAFETY

- a) Whether the width of the staircase is 1.5 mtr.
- b) Whether portable fire extinguisher exists
- c) Whether School building is free from inflammable & toxic material
- d) Whether cooking of food is done at a safe place
- e) Whether any Thatch or combustibile material has bee used

Yes/No ✓  
Yes/No ✓  
Yes/No ✓  
Yes/No ✓  
Yes/No ✓

14. Requirement for Fire Protection Arrangements under NB-Part-IV (For Building height less than 15 metre)

- a) Whether Hose Real provided
- b) Whether down comer provided
- c) Whether Automatic sprinkler provided
- d) Whether underground static water storage tank of capacity 50000 Ltr.(if converted area exceeds 1500 sqm)
- e) Whether over head tank of capacity 10000 Ltr.exists (in case of hose real) 20000 Ltr.
- f) Whether one eclectic and one diesel pump of 3 kg/cum Pressure of capacity 1620 LPM, one electric pump of Capacity 180 LPK exist near underground static tank.
- g) Whether a pump 3 kg/cum pressure & 450/500 LPM Exist near over head tank.

Yes/No ✓  
Yes/No ✓  
Yes/No ✓  
Yes/No ✓  
Yes/No ✓  
Yes/No ✓  
Yes/No ✓  
Yes/No ✓

Principal  
SBS International School  
(Senior Secondary)  
Amritsar, Amritsar.  
BSE  
Affiliation No. 1630657  
School Code - 20640

Signature of the Head of School  
Institute

PART-II

(To be filled by the SDE of PWD (B&R) Department)

- a) I have visited the above mentioned school on dated 7/6/23 and have visually inspected it from all angles of safety and find it fit for normal use as school building.
- b) In case any addition/alteration or expansion and modifications to this buildings is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be reobtained after the completion from the undersigned.
- c) In case the building is affected by flood, or if there is settlement of walls/ foundations or sagging of roofs etc. immediate inspection of the undersigned be arranged to check the stability and safety of the building.
- d) This building can be safely occupied for normal use upto (indicate upto which it can be used) 31<sup>st</sup> March 2024

Sub Divisional Engineer,  
Provincial Sub Division No. 3  
P.W.D.B&R Branch, Amritsar.

Sharandeo/S.L

<http://win10.io>

EXECUTIVE ENGINEER, PROVINCIAL DIVISION, P.W.D. (B&R)  
BRANCH, BATALA ROAD, AMRITSAR

Email: eepdasrpwdpb@gmail.com

To

Principal,  
SBS International School,  
(Senior Secondary),  
Varpal, Amritsar.

Subject:

No. 769

- Dated - 8/6/2023

Building Safety Certificate for the Year 2023-24 i.e. upto 31-03-2024 (SBS International School (Senior Secondary), Varpal, Amritsar).

Reference:

Your office letter No. SBSIS/D/2023-24/16 dated. 16-04-2023.

The Sub Divisional Engineer, Provincial Sub Division No. 3 P.W.D. B&R Br., Amritsar vide his letter No. 59 dated. 07-06-2023 has reported that the building of ("**Shaheed Bhagat Singh International School, Varpal, Tarn Taran Road, Amritsar**") has been inspected and is structurally safe for human inhabitation during the year 2023-24 i.e. upto 31-03-2024. It is also written to you that the Water Cleanness Certificate of your school will expire on 04-09-2023. You are instructed to renew it and register it at the office of the undersigned. In Case of non-conduct, the NOC of your school will be canceled without giving any reason.

DA/ Performa -I&II

Executive Engineer,  
Provincial Division,  
P.W.D. B&R Br., Amritsar.

SLA

Endst. No.

Dated.

Copy of the above is forwarded to Sub Divisional Engineer, Provincial Sub Division No. 3 P.W.D. B&R Br., Amritsar vide his letter No. 59 dated 07-06-2023 for information and necessary action.

DA/ -

Executive Engineer,  
Provincial Division,  
P.W.D. B&R Br., Amritsar.